

E.P. Tom Sawyer Park Pre-Bid Meeting

July 6, 2006

859

[illegible]

**E.P. “Tom” Sawyer Park
Pipe Installation**

Q. Is pipe bedding required?

A. Pipe bedding will not be required on this project.

Q. Where will the Contractor be allowed to access the project?

A. Mike Crain with Parks stated that the main park entrance could be used as access.

Q. Can offsite borrow material be used on the project?

A. Offsite borrow material can be used.

Two borrows areas within 100 yards of the project were identified and discussed with all Contractors at the meeting by Mike Crain with Parks. The borrow areas are to be graded to allow drainage and seeded.

It was reiterated that the Contractor was responsible for locating utilities prior to beginning construction.